



	Pompy	kqt L
P1	Grundfos: SE180.100.75.4.51D 7.5 kW	90°
P2	Grundfos: SEV.80.80.15.4.50D 2.2 kW	90°
P4	Grundfos: SEV.80.80.13.4.50B 1.3 kW	270°
P5	Grundfos: SV 034 DHU 50B 2.9 kW	90° i 270°

ASYSTENT	mgr inż. R. MAĆKOWIAK	DATA OPRACOWANIA	BRANŻA	STADIUM	NR OBIEKTU
ASYSTENT	Ł. JANIĄK	09.2006	SANIT.	PB	I